

Induction Motors: Balanced, Sinusoidal Steady State Operation

- ◆ Line-Fed Operation
 - Characteristics at rated voltage and rated frequency
 - Motor Currents, power factor and efficiency as a function of load
 - Line Start
 - Soft-Start


Characteristics at Rated Voltage and Rated Frequency





- \square Nearly linear near ω_{syn}
- \Box At higher slip (ω_m smaller) leakage inductances and stator resistance reduce torque
- ☐ High currents at low speeds (start-up condition)


Motor Currents, Efficiency, Power Factor As a Function of Load




Typical for design B 10 kW, 4 pole, three-phase induction motor

Line Start

- ☐ When started directly off the line, induction motor draws a very large current (approx. 8 x rated)
- At the same time the torque available to accelerate the motor/load is limited
- ☐ Motor can quickly overheat Solution: Reduced voltage soft start





Current vs. Speed



Accelerating Torque

Reduced Voltage Starting (Soft Start) Energy Savings in Lightly – Loaded Machines





- ☐ Circuit applies reduced voltage to motor during start-up to avoid large currents and over heating
- ☐ Circuit also used to reduce voltage to motor under light load steady state conditions.

 This improves efficiency

Summary

- ◆ Line-Fed Operation
 - Characteristics at rated voltage and rated frequency
 - Motor Currents, power factor and efficiency as a function of load
 - Line Start
 - Soft-Start